



CODE QUIZ

February 2026

1. Per the 2025 California Plumbing Code Table 703.2 the maximum fixture unit loading for a horizontal 3-inch diameter drainage pipe is 35 fixture units, per Table 703.2 footnote 4 the maximum number of water closets is:
 - a. 3
 - b. 4
 - c. 5
 - d. 6
2. Per the 2025 California Building Code Section 306, the assembling, disassembling, fabricating, finishing, manufacturing, packaging, repair or processing operations for the following items are considered Occupancy Group ___: Energy Storage Systems (ESS) and equipment containing lithium-ion or lithium metal batteries, lithium-ion batteries and vehicles powered by lithium-ion or lithium metal batteries.
 - a. F-1 moderate-hazard factory industrial
 - b. F-2 low-hazard factory industrial
3. Per the 2025 California Building Code Section 714.5.1.2 Exception 4, penetrations in a single concrete floor by steel, ferrous or copper conduits, pipes, tubes or vents with a maximum 6-inch nominal diameter do not require a "T" rating. These penetrating items shall not be limited to the penetration of a single concrete floor, provided that the area of the opening through each floor does not exceed 144 square inches.
 - a. True
 - b. False
4. Per the 2025 California Residential Code, Section R308.1, buildings shall be provided with approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. Each character shall be not less than ___ inches in height with a stroke width of not less than ___ inch.
 - a. 3 inches, 0.25 inch.
 - b. 3 inches, 3/8 inch
 - c. 4 inches, 3/8 inch
 - d. 4 inches, 0.5 inch
5. Per the 2025 California Plumbing Code Section 504.4, a water heater installation shall be provided with overpressure protection using an approved, listed device installed in accordance with the terms of its listing and the manufacturer's installation instructions. The pressure relief devices shall have a pressure setting greater than the water service pressure and not exceed ___ psi as required in Section 608.4.
 - a. 80
 - b. 120
 - c. 150
 - d. 200